Features

- 1-channel isolated barrier
- 230 V AC supply
- Dry contact or NAMUR inputs
- Input frequency 1 mHz ... 5 kHz
- · 2 relay contact outputs
- · Start-up override
- · Configurable by keypad
- · Line fault detection (LFD)
- Up to SIL2 acc. to IEC 61508

Function


This isolated barrier is used for intrinsic safety applications. It monitors for an overspeed or underspeed condition of a discrete signal (NAMUR sensor/mechanical contact) from a hazardous area by comparing the input frequency to the user programmed reference frequency.

An overspeed or underspeed condition is signaled via the relay outputs. Line fault detection of the field circuit is indicated by a red LED and relay. The start-up override feature sets relay outputs to default conditions programmed by the user for up to 1,000 seconds.

The unit is easily programmed by the use of a keypad located on the front of the unit.

For additional information, refer to the manual and www.pepperl-fuchs.com.

Assembly









SIL2

Connection





| General specifications | | |
|--|----------------|---|
| Signal type | | Digital Input |
| Supply | | |
| Connection | | terminals 23, 24 |
| Rated voltage | | 230 V AC ± 10 % |
| Rated current | | 18 mA |
| Power loss/power consumption | | ≤2 VA /2 VA |
| Input | | 22 7072 70 |
| Connection | | Input I: intrinsically safe: terminals 1+, 3- |
| Connection | | Input II: non-intrinsically safe: terminals 13+, 14- |
| Input I | | acc. to EN 60947-5-6 (NAMUR) |
| Pulse duration | | > 50 µs |
| Input frequency | | 0.001 5000 Hz |
| Lead monitoring | | breakage I ≤ 0.15 mA; short-circuit I > 6.5 mA |
| Input II | | startup override: 1 1000 s, adjustable in steps of 1 s |
| Active/Passive | | I > 4 mA (for min. 100 ms)/ I < 1 mA |
| | | 18 V / 5 mA |
| Open circuit voltage/short-circuit current | | 10 V / S IIIA |
| Output | | |
| Connection | | output I: terminals 10, 11, 12 |
| Connection | | output II: terminals 16, 17, 18 |
| Output I, II | | signal, relay |
| Contact loading | | 250 V AC / 2 A / cos φ ≥ 0.7; 40 V DC / 2 A |
| Mechanical life | | 5 x 10 ⁷ switching cycles |
| Energized/De-energized delay | | approx. 20 ms / approx. 20 ms |
| Transfer characteristics | | арриям <u>— 2 ма</u> мариям <u>— 2 ма</u> |
| Input I | | |
| • | | 0.001 5000 Hz |
| Measurement range | | 0.1 % of measured value , ≥ 0.001 Hz |
| Resolution | | 0.1 % of measured value , > 0.001 Hz |
| Accuracy | | < 100 ms |
| Measuring time | noroturo | |
| Influence of ambient temperature | | 0.003 %/K (30 ppm) |
| Output I, II | | < 200 ms |
| Response delay | | ≤ 200 ms |
| Electrical isolation | | : (|
| Input I/other circuits | | reinforced insulation according to IEC/EN 61010-1, rated insulation voltage 300 V _{eff} |
| Output I, II against eachother | | reinforced insulation according to IEC/EN 61010-1, rated insulation voltage 300 V _{eff} |
| Output I, II/other circuits | | reinforced insulation according to IEC/EN 61010-1, rated insulation voltage 300 V _{eff} |
| Start-up override/power supply | | reinforced insulation according to IEC/EN 61010-1, rated insulation voltage 300 V _{eff} |
| Directive conformity | | |
| Electromagnetic compatibility | | |
| Directive 2004/108/EC | | EN 61326-1:2006 |
| Low voltage | | |
| Directive 2006/95/EC | | EN 61010-1:2010 |
| Conformity | | |
| Electromagnetic compatibility | | NE 21:2006 |
| Protection degree | | IEC 60529:2001 |
| Ambient conditions | | |
| Ambient temperature | | -20 60 °C (-4 140 °F) |
| Mechanical specifications | | |
| Protection degree | | IP20 |
| Mass | | 300 g |
| Dimensions | | 40 x 119 x 115 mm (1.6 x 4.7 x 4.5 in) , housing type C3 |
| Mounting | | on 35 mm DIN mounting rail acc. to EN 60715:2001 |
| Data for application in connection with Ex-areas | | |
| EC-Type Examination Certificate | | TÜV 99 ATEX 1408 , for additional certificates see www.pepperl-fuchs.com |
| Group, category, type of protection | | \textcircled{k} II (1)GD, I (M1) [Ex ia] IIC, [Ex iaD], [Ex ia] I (-20 °C \leq T _{amb} \leq 60 °C) |
| Supply | | |
| Maximum safe voltage U _m | | 253 V AC (Attention! U _m is no rated voltage.) |
| Input I | | terminals 1+, 3- Ex ia IIC, Ex iaD |
| Voltage | U _o | 10.1 V |
| Current | I _o | 13.5 mA |
| Power | P _o | 34 mW (linear characteristic) |
| Input II | J | terminals 13+, 14- non-intrinsically safe |
| • | | • |

| ┶ |
|-----------------------------|
| $\overline{}$ |
| ٠. |
| 0 |
| 188383_eng.xml |
| ന |
| • |
| ~ |
| 65 |
| œ |
| က |
| œ |
| m |
| \simeq |
| _ |
| |
| |
| $\overline{}$ |
| α |
| |
| Ω |
| 0 |
| 7 |
| S |
| - |
| 2012-05-21 |
| \sim |
| СA |
| |
| o. |
| _ |
| ī |
| ζń |
| .= |
| + |
| Date of issue |
| Ξ |
| Ф |
| ≒ |
| Ľ, |
| ப |
| |
| |
| |
| |
| ₾ |
| 4 |
| 7:17 |
| 7:17 |
| 17:17 |
| 117:17 |
| 21 17:17 |
| -21 17:17 |
| 5-21 17:17 |
| 35-21 17:17 |
| 05-21 17:17 |
| 2-05-21 17:17 |
| 2-05-21 17:17 |
| 112-05-21 17:17 |
| 012-05-21 17:17 |
| 2012-05-21 17:17 |
| 2012-05-21 17:17 |
| 2012-05-2 |
| 2012-05-2 |
| 2012-05-2 |
| 2012-05-2 |
| 2012-05-2 |
| 2012-05-2 |
| 2012-05-2 |
| 2012-05-2 |
| lease date 2012-05-21 17:17 |

| Maximum safe voltage | U_m | 40 V (Attention! The rated voltage can be lower.) |
|---------------------------|----------------|--|
| Output I, II | | terminals 10, 11, 12; 16, 17, 18 non-intrinsically safe |
| Maximum safe voltage | U _m | 253 V (Attention! The rated voltage can be lower.) |
| Contact loading | | 253 V AC/2 A/cos φ > 0.7; 40 V DC/2 A resistive load (TÜV 99 ATEX 1471) |
| Output I, II | | |
| Contact loading | | 50 V AC/2 A/cos φ > 0.7; 40 V DC/1 A resistive load |
| Electrical isolation | | |
| Input I/other circuits | | safe electrical isolation acc. to IEC/EN 60079-11, voltage peak value 375 V |
| Directive conformity | | |
| Directive 94/9/EC | | EN 60079-0:2009, EN 60079-11:2007, EN 60079-15:2005, EN 60079-26:2007, EN 61241-11:2006 |
| International approvals | | |
| FM approval | | |
| Control drawing | | 16-538FM-12 |
| General information | | |
| Supplementary information | | EC-Type Examination Certificate, Statement of Conformity, Declaration of Conformity, Attestation of Conformity and instructions have to be observed where applicable. For information see www.pepperl- |